



75
Azadi Ka
Amrit Mahotsav

ਦਫਤਰ ਕਾਰਜਕਾਰੀ ਇੰਜੀਨੀਅਰ
ਪ੍ਰਾਂਤਕ ਮੰਡਲ ਭ ਤੇ ਮ ਸ਼ਾਖਾ,
ਫਿਰੋਜ਼ਪੁਰ 01632-292529

ਲੋਕ ਨਿਰਮਾਣ ਵਿਭਾਗ ਪੰਜਾਬ

E-Mail ID- eepdfzrpwdpb@gmail.com

OFFICE OF EXECUTIVE ENGINEER
Provincial Division PWD B&R Br,

Ferozepur 01632-292529

ਪਿੱਠ ਅੰਕਣ ਨੰ: 977-78

ਮਿਤੀ: 5/6/2023

ਉਪਰੋਕਤ ਦਾ ਉਤਾਰਾ ਹੇਠ ਦਰਸਾਇਆ ਨੂੰ ਸੂਚਨਾ ਅਤੇ ਲੋੜੀਂਦੀ ਕਾਰਵਾਈ ਹਿੱਤ ਭੇਜਿਆ ਜਾਂਦਾ ਹੈ:-

1. Principal, Shree Atam Vallabh Jain Vidyamandir Zira, Distt. Ferozepur.
ਨੱਥੀ/ਨਕਸ਼ਾ ਮੂਲ ਰੂਪ ਵਿੱਚ
2. ਉਪ ਮੰਡਲ ਇੰਜੀਨੀਅਰ, ਉਸਾਰੀ ਉਪ ਮੰਡਲ, ਭ ਤੇ ਮ ਸ਼ਾਖਾ, ਜ਼ੀਰਾ ਨੂੰ ਉਹਨਾਂ ਦੇ ਪੱਤਰ ਨੰ: 111
ਮਿਤੀ: 02.06.2023 ਦੇ ਹਵਾਲੇ ਵਿੱਚ ਸੂਚਨਾ ਹਿੱਤ।

ਕਾਰਜਕਾਰੀ ਇੰਜੀਨੀਅਰ,
ਪ੍ਰਾਂਤਕ ਮੰਡਲ, ਭ ਤੇ ਮ ਸ਼ਾਖਾ
ਫਿਰੋਜ਼ਪੁਰ

- b) Weather portable fire extinguisher exists. : YES/ NO
- c) Weather School building is free from inflammable & toxic material : YES/ NO
- d) Weather cooking of food is done at a safe place. : YES/ NO
- e) Weather any thatch of combustible material has been used : YES/ NO
14. **Requirement for Fire Protection Arrangements under NBC** : YES/ NO ✓
- Part IV**
(For Building height less than 15 Mtr.)
- a) Weather Hose Real provided : YES/ NO ✓
- b) Weather down comer provided : YES/ NO ✓
- c) Weather automatic sprinkler provided. : YES/ NO ✓
- d) Weather underground static water storage tank of capacity 50000 Ltr. (if converted are excess 1600 Sqm). : YES/ NO ✓
- e) Weather over head tank of capacity 10000 Ltr. Exists (in case of hose real) 20000 Ltr. : YES/ NO
- e) Weather one electric and one diesel Pump of 3 Kg/ cum pressure of capacity 1620 LPM. One electric pump of capacity 180 LPM exist near underground static tank. : YES/ NO
- g) Weather a pump 3 kg/ cum pressure & 450/500 LPM exist near over head tank. : YES/ NO

seal

Signature with Stamp of the
Principal
Of the School/Institution
Shree Atam Vahan Jain Vidyamandir
Zira

PART-II

(To be filled by the S.D.E. of PWD (B&R) Department)

- a) I have visited the above mentioned school on dated ..01.06.2023..... And have visually inspected it from all angles of safety and find it fit for normal use as School buildings.
- b) In case any addition/ alteration or expansion and modifications to this buildings is to be carried out, the same be carried out under the supervision of a qualified Engineer and this certificate may be reobtained after the completion from the undersigned.

- c) In case the building is affected by food, or if there is settlement of walls/ foundations or sagging of roofs etc. immediate inspection of the undersigned by arranged to check the stability and safety of the building.
- d) This building can be safety occupied for normal use upto (indicate upto which it can be used) 20/3/2024.....

Ob
Sub Divisional Engineer
Sub Divisional Engineer
P.W.D. (B&R) Branch.
P.W.D. (B&R) Branch.
ZARA