

**PROFORMA REGARDING SAFE DRINKING WATER AND SANITARY CONDITION  
CERTIFICATE.**

No. DWTL FZE/092/2024-25.

Date: 02/04/2024

It is certified that an inspection team headed by Harpreet Singh  
Lab Chemist, Distt. Water Testing Laboratory, Ferozepur (Name of Officers  
with designation) from Water Supply & Sanitation Deptt, FZ (Name of  
Department/Office) inspected the Sh. Atam Vallabh Jain Vidya  
Mandir, Zirra, Distt- Ferozepur (Name & Address of  
the School) on 02/04/2024 and found that the Sh. Atam Vallabh  
Jain Vidya Mandir (Name of school) has safe  
drinking water facilities for the students and members of staff of the institution and is maintaining  
the hygienic sanitation condition in the school building & the campus as per the norms  
prescribed by the Central State/U.T. Govt.

The above valid for a period of one year i.e

02/04/2024 to 01/04/2025.

Signature with Seal

Name

Designation

Harpreet Singh  
Lab Chemist/J.E. Incharge  
Distt. Water Testing Laboratory  
W/s & Sanitation Deptt.  
Ferozepur.

: Harpreet Singh

: Lab Chemist

To

The Principal  
Sh. Atam Vallabh Jain Vidya mandir,  
Zirra, Distt- Ferozepur.

(Name & Address of the Institution)

**WATER SUPPLY & SANITATION DISTRICT LEVEL WATER TESTING  
LABORATORY  
ANALYSIS REPORT OF WATER SAMPLES**

**Particulars of Samples**

Sample No. 1

Sample No. 2

Date of  
Receipt

Date of  
Conducting

01/04/24    01/04/24

1 Place/Name of Village

Sh. Atkam Vallabh Jain Society, Zira.

2 Block/District

Zira / Faridkot

3 Source

R.O.

4 Date and time of collection

01/04/2024

5 Depth

-

6 Spring Level

-

7 Name and designation of the  
Person collecting the sample

Sh. Harish Jain (manager)

**TEST RESULTS**

**PHYSICAL AND CHEMICAL**

1 Turbidity (JTU)

-

2 Colour (Units on Pt-Co Scale)

-

3 Taste and odors (Qualitative)

-

4 PH

6.8

5 Total Dissolved Solids mg/l

074

6 Total Alkalinity (as CaCo<sub>3</sub>) mg/l

32

7 Hardness (as CaCo<sub>3</sub>)mg/l

-

(a) Total

20

(b) Calcium

06

(c) Magnesium

-

(d) Carbonate

-

(e) Non-Carbonate

-

P.T.O.

8 Chlorides (as/Cl) mg/l	10	.....	.....
9 Sulphates (as So4) mg/l	-	.....	.....
10 Fluorides (as F) mg/l	0.14	.....	.....
11 Nitrate (as No.3) mg/l	-	.....	.....
12 Iron (as.Fe.) mg/l	-	.....	.....
13 Residual Chlorine (as Cl) mg/l	-	.....	.....
14 Conductivity micromhos/cm	-	.....	.....

**BACTERIOLOGICAL**

1 Plate Eount (colonies/ml)	/	/
2 Caliform Organisms (MPN/100 ml)	/	/

Remarks : (In view of the above analysis)


**Sample No : 1**

- 1 The water is potable / ~~not potable~~.
- 2 The following parameters are more than the acceptable, but less than the cause for rejection limits.

**Sample No : 2**

- 1 The water is potable / not potable.
- 2 The following parameters are more than the acceptable, but less than the cause for rejection limits.

ATTESTED

  
 Lab Chemist/J.E. Incharge  
 Distt. Water Testing Laboratory  
 CHEMIST/J.E. Incharge  
 Water Supply & Sanitation Deptt.  
 District Level Water Testing Laboratory,  
 Ferozepur.

SAMPLE CONSUMED IN TESTING